



Whitemarsh TOWNSHIP

616 GERMANTOWN PIKE – LAFAYETTE HILL, PA 19444-1821
TEL: 610-825-3535 FAX: 610-825-9416
www.whitemarshtwp.org

BOARD of SUPERVISORS

Laura Boyle Nester – Chair
Fran McCusker – Vice Chair
Michael Drossner
Vincent Manuele
Jacy Toll

Richard L. Mellor, Jr.
Township Manager

Fire Marshal's Office Novelty Fireworks Retail Sales Check List

This checklist provides frequently questioned items and is not an all-encompassing document with all requirements of the PA UCC or Whitemarsh Ordinances.

- Generator shall be separated by a minimum of 20 feet from the tent & shall have an approved enclosure to prevent access from the public
- Tents shall be anchored adequately
- No storage within 3 feet of the tent walls on the interior
- Emergency lighting required in all tents
- Illuminated Exit signs required in temporary structures with square footage of 3,000 or more
- Tents shall have a flame propagation certification
- "No Smoking" signs required
- A minimum of two 5 LB ABC fire extinguishers are required
- The site shall be secured adequately
- Storage container shall be a minimum of 20 feet from the tent and the generator
- Storage container shall be placarded on all four sides

If you have any questions, please call the Fire Marshal's Office at 484-594-2614