



# Whitemarsh TOWNSHIP

616 GERMANTOWN PIKE – LAFAYETTE HILL, PA 19444-1821  
TEL: 610-825-3535 FAX: 610-825-9416  
[www.whitemarshtwp.org](http://www.whitemarshtwp.org)

## BOARD of SUPERVISORS

Laura Boyle Nester – Chair  
Fran McCusker – Vice Chair  
Michael Drossner  
Vincent Manuele  
Jacy Toll

Richard L. Mellor, Jr.  
Township Manager

## Fire Permit Inspection List

***If you have any questions, please call the Fire Marshal's Office at 484-594-2614***

### ***Fire Alarm (NFPA 72)***

1. Function Test
2. 24 Hour Battery Test
3. Submission of NFPA 72 Record of Completion

### ***Sprinkler System (NFPA 13)***

1. Above Ceiling Inspection (Rough)
2. Hydrostatic Test
3. Air Pressure Leakage Test (Dry Systems Only)
4. Dry Trip Test (Dry Systems Only)
5. Main Drain/Final Inspection
6. Submission of Aboveground Piping Certification

### ***Underground Fire Main (NFPA 24)***

1. Open Ditch
2. Flush/Flow
3. Hydrostatic Test
4. Submission of Underground Piping Certification

### ***Hydrant (NFPA 24)***

1. Flow Test
2. Submission of Underground Piping Certification

### ***Dry Chemical System (NFPA 17)***

1. Balloon Test
2. Submission of Acceptance Inspection Report

### ***Wet Chemical System (NFPA 17A)***

1. Light/Smoke Test of Duct Work
2. Balloon Test
3. Submission of Acceptance Inspection Report

### ***Standpipe (NFPA 14)***

1. Flush
2. Hydrostatic Test
3. Flow Test
4. Submission of Aboveground Piping Certification

### ***Fire Pump (NFPA 20)***

1. Flush
2. Hydrostatic Test
3. Field Acceptance Test
  - a. Certified Pump Curve needed (Bench Test)
4. Submission of Pump Test Results
  - a. Above or Underground Piping Certification (If needed)

### ***Residential Sprinklers (NFPA 13D)***

1. Residential UG Fire Mains only require a flush
2. Open Ceiling (Rough)
3. Final (Bucket Test)
4. Submission of Aboveground Piping Certification